

## This is to certify that

**EMDION GmbH**  
**Emden, Germany**

is granted acceptance for  
**Inspection and maintenance of fire extinguishing equipment and systems , in accordance with Class Programme DNV-CP-0624.**

This service supplier certificate will be accepted for use with all rule sets published by DNV.  
**See the following page(s) for details regarding application.**

This Certificate is valid from **2022-12-03** to (inclusive) **2025-12-02**.

This Certificate is issued on **2023-05-10**.



for **DNV**

This document has been digitally signed and will  
therefore not have handwritten signatures

**Kühne, Dennis**  
**Surveyor**

This Certificate may be withdrawn if:

1. The service provided has been improperly carried out or the results improperly reported.
2. The surveyor has found any deficiencies in the accepted operating systems of the service supplier.
3. The firm has failed to inform of any major changes having effect on the quality of the service rendered.
4. The conditions listed in the certificate are changed and/or are not fulfilled.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Form code: AOSS 101

Revision: 2022-12

www.dnv.com

Page 1 of 2

## Application:

Survey and Maintenance of Fire Extinguishing Equipment and Systems:

- CO2 Fire Extinguishing Systems (High- and Low Pressure)
- Halon and other Gaseous Fire Extinguishing Systems
- Foam Fire Extinguishing Systems
- Dry Powder Fire Extinguishing Systems
- Pressure Water Spraying Systems (Sprinkler and Deluge) incl. Water Mist Systems
- Portable and Mobile Fire Extinguishers
- Fire Detection and Alarm Systems

## Remarks:

It is in the obligation of the company that outsourced parts of the services e.g., pressure testing of gas cylinders and examination of foam concentrates shall comply with the requirements as per IACS UR Z17 and DNV-CP-0624. Evidence is to be provided for each case.